



**ADDENDUM NO. 5**

**DATE:** December 14, 2022  
**OWNER:** City of Ozark  
205 N. 1<sup>st</sup> Street  
Ozark, MO 65721  
**SUBJECT:** Addendum No. 5 – 2022 Sanitary Sewer Treatment & System Improvements  
Cochran Project No. SW17-120/SW19-204

---

This Addendum forms a part of the Bidding and Contract Documents and modifies the original Bidding Documents.  
**FAILURE TO ACKNOWLEDGE RECIEPT OF ADDENDUM MAY SUBJECT BIDDER TO DISQUALIFICATION.**

---

**GENERAL**

1. Further clarification to Contractor’s question regarding the conveyor motor.  
There are two (2) 5 hp motors on the conveyor system. One is one on the end of the incline conveyor and one is on the end of the horizontal conveyor. Each motor will require a 20 amp circuit with #12 wire. The motor on the horizontal conveyor will not require a local disconnect switch. Only the motor on the incline conveyor which is located on the exterior of the building will require a local disconnect switch.

**For a contractor’s bid to be considered, the contractor must prove they have installed a centrifuge in the past 10-years and have extensive experience with wastewater treatment plant construction.**

**END OF ADDENDUM NO. 5**